



AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : CP-2020-06-30-79 Date: 20/05/2020
Customer : Assistant Executive Engineer, Yelahanka Satellite Town Sub Division, BBMP, Bangalore.
Address : Yelahanka Satellite Town Sub Division, BBMP, Bangalore.
Project Name : Construction of CC Roads in Ward No:04 Yelahanka Satellite Town Sub Division
Agency : Sri.G.Venkateshgowda, No:531/1, 14th A Cross, A Sector, Yelahanka New Town, Bangalore-64
Customer's Reference : BBMP/HO/YNK.D/EPMT-16/W/O/07/2020-21
Source of Sample : Sample supplied by Agency
Sample Condition : Satisfactory
Date of Receipt : 15-05-20
Customer ID : Drain Bottom Slab Concrete
Sample Type /Size : 150X150X150 mm
Sample grade/Age : M20 / 7 Days Compressive Strength
Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test : 20/05/2020

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm ²)	Average Compressive Strength (N/mm ²)
1	Drain Bottom Slab Concrete	M20	13/05/2020	20/05/2020	151.02 X 149.40 X 151.61	22562	8.733	417.4	18.5	18.4
2	Drain Bottom Slab Concrete	M20	13/05/2020	20/05/2020	149.16 X 151.26 X 151.58	22562	8.794	413.5	18.3	
3	Drain Bottom Slab Concrete	M20	13/05/2020	20/05/2020	149.53 X 150.07 X 149.06	22440	8.741	414.9	18.5	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

ಸಹಾಯಕ ಕಾರ್ಯದರ್ಶಿ
ಯಲಹಂಕ ಸಾಟಲೈಟ್ ಟೌನ್
ಬಿ.ಬಿ.ಎಂ.ಪಿ. ಬೆಂಗಳೂರು-106



FOR CIVIL Pro.
R. Rudraprasad
Authorized Signatory
Technical Manager

Page 1/1
****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |